

TOWN OF MILTON
MEETING MINUTES OF THE BOARD OF HEALTH
February 9, 2023
5 p.m.
Remote via Zoom

Attending:

Laura T. Richards, Esq., Chair
Mary F. Stenson, R.N., BSN, Secretary
Roxanne Musto, RN-C, MS, ANP, Member
Caroline Kinsella, BSN, RN, RS, Health Director, Public Health Nurse
Laura DelleChiaie, BS, Assistant Health Director
Joyce Krystofolski, Health Agent

1. Call to Order:

The Meeting was called to order at 5:02 p.m.

2. Local Upgrade Approval Request for Septic System Repair – 1380 Blue Hill Avenue

Engineer George Collins requested a local upgrade approval from section 310 CMR 15.221 of the State Sanitary Code which requires a maximum 36” of cover over all system components. A local upgrade approval allowing up to 68” of cover over the tanks is requested. (H-20 provided). 2. Local Upgrade Approval from section 310 CMR 15.227 of the State Sanitary Code which requires a minimum 12” vertical separation between the high ground water elevation and the lowest tank invert. A variance allowing a reduction from 12” to a minimum of 2” is requested. The Board unanimously approved.

1. Adjournment:

The meeting adjourned at 5:25 p.m.

Mary F. Stenson, Secretary

